

Government of India
Ministry of Commerce & Industry
Department of Commerce
Directorate General of Supplies & Disposals

Telephone : 011-23163513, 33361799

Fax

Telegram -

E Mail

Website : dgsd.gov.in

Director(QA), Delhi Directorate,

Jeevan Tara Building, 4th Floor, Sansad Marg
New Delhi-110001**REGISTRATION CERTIFICATE**

Dated: 12-AUG-08

To
 M/s ATC CABLES (Supplier Code : 04205)

CU-39, Pitampura,

DELHI

110088

Ref:- Your Application No. ATC/56

Dated 17 MAR 08

Dear sir,

Your request for registration with Directorate General of Supplies & Disposals (DGS&D) has been accepted and your name has been included in the list of registered suppliers as per details given hereunder and in the attached Schedule

Registration No. : DGS&D/Regn/DEL/S-2921/08/04205 Valid upto : As indicated

Category of registration : Manufacturer

workwise
Whether SSI Unit : Yes

Name of the firm : ATC CABLES

Office Address, E-Mail ID, Telephone nos.

a) Registered Office

CU-39, Pitampura,

DELHI

09910501899, 09312253810

atc.cables@gmail.com

b) Corporate/Head Office

CU-39, Pitampura,

DELHI

09910501899, 09312253810

atc.cables@gmail.com

c) Correspondence Address

Date of incorporation : 10 MAR-07

Constitution of the firm : Partnership

Name of Managing Director/Partner/Proprietor

1 Sunil Sood

2 Mr. Sushil Sood

Mr. Davinder Sood

Permanent Account No. (PAN): AAQFA0722F

Annual Turnover

: Year

Rs. (In Lacs)

2007-08

470.76

With Profit

Monetary Limit (Rs in Lacs): Without any limit

The registration is subject to Conditions of Registration as enclosed and as prescribed by DGS&D from time to time. Stores will be offered for customer's testing and inspection at the premises specified in the Schedule. This Certificate is to be produced only in full and complete with amendments if any. Please quote your registration no. in all future correspondence with DGS&D.

Yours faithfully,

(Signature)
 12/08/08
 Deputy Director (Registration)
 for Director General of Supplies & Disposals

उप निदेशक गु.जा.०
 By: Director Quality Assurance
उप निदेशक (गुणता आश्वासन)
 Director (Quality Assurance)

File to Registration No. DEL/B-2921/08/04205

Dated 12-AUG-08

No Works Name & Address

Validity 10-AUG-09

1 ATC Cables

Vill. Bhurranwala, P.O. Barotiwala, Tehsil: Kasholi,
Solan

9816013850, 9218413850

Sales tax registration No.

Date

CST registration No.


SOL-III-11142, SOL-CST-10981

Date

Excise Duty Registration No. -

Authority

S.No	Description of Stores	Governing Specification/ Eligibility Criteria	Model/ Brand	Prod. Capacity/ Dt. of Approval
1	PVC Insulated, Unarmoured or Armoured, PVC sheathed electric cable for working voltage up to and including 1100 V.	Specification : PVC insulated armoured / un armoured and PVC sheathed (general purpose) multicore cable with stranded aluminium / copper conductor conforming to IS:1554 (part 1)/88.	Brand: ATC	-- 12-AUG-08
2	Twin Core Unarmoured with inner sheath XLPE Cables.	Cross Linked Polyethelene (XLPE) insulated, PVC Outer Sheathed (ST2) Cable with aluminium conductor suitable for rated voltage at 1100 volts grade and conforming to IS:7098 (Part-1)/1988 with amdt.no.1	Brand: ATC	12-AUG-08
3	Two core armoured XLPE Cables.	Cross Linked Polyethelene (XLPE) insulated, PVC Outer Sheathed (ST2) armoured with galvanized steel strip and with aluminium conductor suitable for rated voltage at 1100 volts grade and conforming to IS:7098 (Part-1)/1988 with amdt.no.1	Brand: ATC	-- 12-AUG-08
4	Three and half core circular armoured XLPE Cables.	Cross Linked Polyethelene (XLPE) insulated, PVC Outer Sheathed (ST2) armoured with galvanized steel strip and with aluminium conductor suitable for rated voltage at 1100 volts grade and conforming to IS:7098 (Part-1)/1988	Brand: ATC	12-AUG-08



उप निदेशक गु.म.ता
 Dy. Director Quality Assurance
 एवं निदेशक (गुणता आश्वासन)
 Dir Director (Quality Assurance)

with amdt.no.1


- | | | | | |
|---|--|---|---------------|---|
| 5 | Non Weather Proof
Unarmoured PVC Insulated
Al. Conductor Cable | Specification: Unarmoured
PVC insulated single core
cable with aluminium /
copper conductor for
working voltage upto and
including 1100 Volt and
conforming to IS 694/90
with amendment number 1 &
2 . Conductor shall be
conforming to IS: 8130/84
table I and table II as
applicable | Brand:
ATC | 200 KM /
Shift/Month
assorted size

12-AUG-08 |
| 6 | Single Core Unarmoured
XLPE Cables. | Cross Linked Polyethelene
(XLPE) insulated, PVC
Outer Sheathed (ST2)
Cable with aluminium
conductor suitable for
rated voltage at 1100
volts grade and
conforming to IS:7098
(Part-1)/1988 with
amdt.no.1 | Brand:
ATC | 50
KM/Shift/Month
assorted size
for Items XI,PT
CABLES AND PVC
CABLES

12-AUG-08 |

No. of items registered (work wise): 6

* ANNEXURE Attached




मुख्य निर्देशक गुणता
 Dy. Director Quality Assurance
 मुख्या निर्देशक (गुणता आश्वासन)
 Director (Quality Assurance)

to:

1. Director of Quality Assurance, [controlling officer]
2. Director of Supplies (concerned purchase Dto(s), DGS&D, New Delhi.
3. Director (Registration) / Director (MIS) DG (S&D), New Delhi
4. Guard File

Please Note:

1. This supersedes the earlier Registration Certificate if any
2. This registration is an indication of the capability of the registered firm. For further assurance on quality, the Purchasers are advised to avail the inspection services offered by the Quality Assurance Wing of DGS&D.
3. Authenticity of this certificate can be verified by the government indentors and purchasers by logging on DGS&D website "<http://www.dgsnd.gov.in>".
4. Onus for verification of the firm's ITCC before award of Contract will rest with the purchaser.



मुख्य निदेशक गुणता
By Director Quality Assurance
मुख्य निदेशक (गुणता आश्वासन)
The Director (Quality Assurance)

ANNEXURE

ATC Cables

VIII. Bhurranwala, P.O. Barodwala, Tehsil: Kaskool,
Solani

9816013850, 9218413850

PVC Insulated, Unarmoured or Armoured, PVC sheathed electric cable for working voltage up to and including 1100 V.

Limiting Size / Grade / Type

- 1 Type: PVC Insulation - type A, Outer Sheath - PVC ST 1, Size: 2 Core x 6 Sq.mm, Un armoured, Copper conductor.
- 2 Type: PVC Insulation - type A, Outer Sheath PVC ST 1, Size: 2 Core x 25 Sq.mm, strip armoured, Aluminium conductor.

Twin Core Unarmoured with inner sheath XLPE Cables.

Limiting Size / Grade / Type

- 1 2 Core x 6 Sq.mm (Solid) to 2 Core x 25 Sq.mm (Stranded)

Two core armoured XLPE Cables.

Limiting Size / Grade / Type

- 1 2 Core x 6 Sq.mm (Solid) to 2 Core x 120 Sq.mm (Stranded)

Three and half core circular armoured XLPE Cables.

Limiting Size / Grade / Type

- 1 Three and half core x 25 Sq.mm to Three and half core x 240 Sq.mm (Stranded)

Non Weather Proof Unarmoured PVC Insulated Al. Conductor Cable


Limiting Size / Grade / Type

- 1 Non Weather Proof Insulation type A (PVC)
Size: 1 Core x 2.5 Sq.mm Aluminium conductor
- 2 Non Weather Proof Insulation Type A (PVC).
Size: 1 core x 1.5 Sq.mm Copper conductor
- 3 Non weather proof, Insulation type A (PVC) Outer Sheath PVC (ST1).
Size: 3 Core x 0.75 Sq.mm Copper conductor

Single Core Unarmoured XLPE Cables.

Limiting Size / Grade / Type

- 1 Single core x 6 Sq.mm (Solid) to Single Core x 240 Sq.mm (Stranded & Shaped)



सुब निदेशक गुणवत्ता
By Director Quality Assurance
सुब निदेशक (गुणवत्ता आश्वासन)
Director (Quality Assurance)